THIRD FLOOR VARIABLE AIR VOLUME BOX SCHEDULE

SYMBOL	MANUFACTURER & MODEL NO.	INLET SIZE	DISCHARGE SIZE	TERMINAL UNIT			HOT WATER COIL			BTU	WEIGHT LBS.	ANCHORAGE DETAIL	REMARKS
				DESIGN CFM	MAX CFM	MIN CFM	E.W.T. °F	L.W.T. °F	GPM				
VAV 3-1	TITUS DESV-9	9	14x12.5	800	1050	240	180	140	1.3	25,920	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-2	TITUS DESV-10	10	14x12.5	915	1400	275	180	140	1.5	29,646	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-3	TITUS DESV-10	10	14x12.5	915	1400	275	180	140	1.5	29,646	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-4	TITUS DESV-9	9	14x12.5	800	1050	240	180	140	1.3	25,920	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-5	TITUS DESV-9	9	14x12.5	800	1050	240	180	140	1.3	25,920	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-6	TITUS DESV-9	9	14x12.5	800	1050	240	180	140	1.3	25,920	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-7	TITUS DESV-9	9	14x12.5	800	1050	240	180	140	0.7	25,920	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-8	TITUS DESV-12	12	16x15	1480	2000	445	180	140	2.4	47,952	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-9	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-10	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-11	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-12	TITUS DESV-10	10	14x12.5	810	1400	245	180	140	1.3	26,244	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-13	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-14	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-15	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-16	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-17	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-18	TITUS DESV-8	8	12x10	700	900	210	180	140	1.1	22,680	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-19	TITUS DESV-8	8	12x10	535	900	160	180	140	0.9	17,334	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-20	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-21	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-22	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-23	TITUS DESV-8	8	12x10	535	900	160	180	140	0.9	17,334	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-24	TITUS DESV-08	8	12x10	475	900	145	180	140	0.8	15,390	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-25	TITUS DESV-8	8	12x10	600	900	180	180	140	1.0	19,440	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-26	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-27	TITUS DESV-10	10	14x12.5	840	1400	250	180	140	1.4	27,216	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-28	TITUS DESV-06	6	12x8	230	500	70	180	140	0.4	7,452	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-29	TITUS DESV-10	10	14x12.5	840	1400	250	180	140	1.4	27,216	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-30	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-31	TITUS DESV-10	10	14x12.5	900	1400	270	180	140	1.5	29,160	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-32	TITUS DESV-10	10	14x12.5	890	1400	890	180	140	1.4	28,836	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-33	TITUS DESV-12	12	16x15	1460	2000	440	180	140	2.4	47,304	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-34	TITUS DESV-08	8	12x10	400	900	120	180	140	0.6	12,960	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-35	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-36	TITUS DESV-12	12	16x15	1220	2000	365	180	140	2.0	39,528	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-37	TITUS DESV-10	10	14x12.5	1130	1400	340	180	140	1.8	36,612	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-38	TITUS DESV-08	8	12x10	440	900	130	180	140	0.7	14,256	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-39	TITUS DESV-10	10	14x12.5	980	1400	295	180	140	1.6	31,752	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-40	TITUS DESV-06	6	12x8	300	500	90	180	140	0.5	9,720	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-41	TITUS DESV-08	8	12x10	500	900	150	180	140	0.8	16,200	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-42	TITUS DESV-10	10	14x12.5	970	1400	290	180	140	1.6	31,428	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-43	TITUS DESV-10	10	14x12.5	950	1400	285	180	140	1.5	30,780	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-44	TITUS DESV-12	12	16x15	1200	2000	360	180	140	1.9	38,880	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-45	TITUS DESV-12	12	16x15	1600	2000	480	180	140	2.6	51,840	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.
VAV 3-46	TITUS DESV-06	6	12x8	345	500	105	180	140	0.6	11,178	15	N/A ∠20 LBS.	PROVIDE PRESSURE INDEPENDENT AIR TERMINAL WITH 2 ROW HOT WATER COIL. CONTROLLER (PROVIDED BY EMS MANUFACTURER) INSTALLED AT FACTORY BY VAV MANUFACTURER WITH TRANSFORMER (COORDINATE WITH EMS MANUFACTURER), AND DISCONNECT SWITCH.

SADDLEBACK COLLEGE

gkkworks
2355 Main Street Suite 220
Irvine | CA 92614
949 250 1500
949 955 2708 fax

Architect Seal

Consultant and Seal

REGISTERED PROFESSIONAL ENGINEER No. E-9345 MECHANICAL STATE OF CALIFORNIA

Fundament & Associates Inc.
Engineering Consultants
26 Executive Park, Suite 100, Irvine CA 92614 (949) 251-1131

Agency Approval

ARCHITECTURAL STAMP
DIV OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
04 109129
ACCN
DATE MAY 07 2008

No.	Date	Revision/Issue

Project Name

JAMES B. UTT MEMORIAL LEARNING RESOURCE CENTER RENOVATION

28000 Marguerite Parkway
Mission Viejo, California 92692

Checked By | Drawn By

Sheet Title

MECHANICAL EQUIPMENT SCHEDULES

Sheet Number

M0.04

Project Number: 04-111 | Scale: N.T.S.

©2008 gkkworks, All Rights Reserved
NO PART OF THE CONTENTS OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE WRITTEN PERMISSION OF GKKWORKS.

OR331777-51697 P1 S2 - R C CONSTRUCTION SERVICES - PG 149 OF 235 (P1 S2) 1 SET.TIF - 2/3/2010 - 15:34

J:\7113-Saddleback Library\Mech\M004.dwg 04/16/2008