PANEL "HA"

MAIN 200A, 3P — BUSS 225A CU. — SERVICE 480/277V, 3Ø, 4W — LOCATION ADMINISTRATION BLDG. — MOUNTING SURFACE — A.I.C. 14,000

DESCRIPTION	VOLT AMPS A	B	C	LTG	RECP	MOT	BKR POLE	AMP	CKT NO.	A B C	CKT NO.	BKR POLE	AMP	LTG	RECP	MOT	VOLT AMPS A	B	C	DESCRIPTION
OFN OFF.CORRSTOR LT.	1203			19			1	20	1		2	20					1522			AC-2A
OFF.CONF.RR.RETAIL LT.		1686		25			1	20	3		4							2522		9.1 FLA
* EXT. WALL MTD. LIGHTS			569	11			1	20	5		6	3							2522	-----
* EXTERIOR CANOPY LTS.	516			6			1	20	7		8		70			1	3000			TRANSFORMER "TA"
LIGHTING CONTROL		200				1	1	20	9		10							5000		45 KVA
WH-3(MEN'S)			5500			1	1	30	11		12	3							5000	-----
WH-3(WOMEN'S)	5500					1	1	30	13		14		20				-			SPARE
SPARE		-					1	20	15		16		20					-		SPARE
SPARE			-				1	20	17		18		20						-	SPARE
SPARE	-						1	20	19		20		-				-			SPACE
SPARE		-					1	20	21		22		-					-		SPACE
SPARE			-				1	20	23		24		-						-	SPACE
SPACE	-						1	-	25		26		-				-			SPACE
SPACE		-					1	-	27		28		-					-		SPACE
SPACE			-				1	-	29		30		-						-	SPACE
SPACE	-						1	-	31		32		-				-			SPACE
SPACE		-					1	-	33		34		-					-		SPACE
SPACE			-				1	-	35		36		-						-	SPACE
SPACE	-						1	-	37		38		-				-			SPACE
SPACE		-					1	-	39		40		-					-		SPACE
SPACE			-				1	-	41		42		-						-	SPACE
TOTALS:	7221	1886	6069														1522	1522	1522	
																	TOTALS:	24745	9408	23591
																		A	B	C

11,342 V.A. (L.G.L) x 125 = 14,428 V.A.
OTHER LOAD = 56,200 V.A.
TOTAL = 70,628 V.A. TOTAL AMPS 85

* NOTE: PROVIDE TIME SWITCH "TORK #DZ5400A" AND CONTACTORS, SQUARE D CLASS 8903 TYPE LG40 (3 EA.) TO CONTROL EXTERIOR LIGHTING CIRCUITS HA-5a, HA-5b & HA-7 (EACH ON A SEPARATE CHANNEL.) MOUNT TIME SWITCH AND CONTACTORS IN TOP OF PANEL "HA" IN SEPARATE BARRIERED COMPARTMENT WITH DOOR LOCK KEYED TO MATCH PANEL. CONNECT TIME SWITCH AND LIGHTING CONTACTOR CONTROL CIRCUIT TO HA-4.

PANEL "HC"

MAIN 400A, 3P — BUSS 400A CU. — SERVICE 480/277V, 3Ø, 4W — LOCATION CONCESSION — MOUNTING SURFACE — A.I.C. 14,000

DESCRIPTION	VOLT AMPS A	B	C	LTG	RECP	MOT	BKR POLE	AMP	CKT NO.	A B C	CKT NO.	BKR POLE	AMP	LTG	RECP	MOT	VOLT AMPS A	B	C	DESCRIPTION
STORRM.JAN.ELEC. LTS.	816			8			1	20	1		2		30	6			8600			SOCCER ARENA 1 LTS.
KITCHEN.SERVING LTS.		586		8			1	20	3		4			5				5500		SOCCER ARENA 1 LTS.
* BUILDING FACADE LTS.			406	7			1	20	5		6	3		5					5500	SOCCER ARENA 1 LTS.
* CANOPY LIGHTS	406			7			1	20	7		8		30	5			5500			SOCCER ARENA 1 LTS.
LIGHTING CONTROL		200					1	20	9		10			6				6600		SOCCER ARENA 1 LTS.
* MLA MAINT. LTS.			938	2			1	20	11		12	3		5					5500	SOCCER ARENA 1 LTS.
* MLB MAINT. LTS.	938			2			1	20	13		14		30	6			8600			SOCCER ARENA 2 LTS.
SOCCER SEATING LTS.		1026		19			1	20	15		16			5				5500		SOCCER ARENA 2 LTS.
MINOR LEAGUE SEATING			324	6			1	20	17		18	3		5					5500	SOCCER ARENA 2 LTS.
TOT LOT AREA 1 LIGHTS	620			30			1	20	19		20		30	5			5500			SOCCER ARENA 2 LTS.
TOT LOT AREA 2 LTS.		1944		36			1	20	21		22			5				5500		SOCCER ARENA 2 LTS.
MZ-MA			2500			1		20	23		24	3		6					6600	SOCCER ARENA 2 LTS.
MINOR LEAGUE A	2500						2		25		26	1	20				-			SPARE
MZ-MB		2500				1		20	27		28	1	20					-		SPARE
MINOR LEAGE B			2500				2		29		30	1	20						-	SPARE
GHJ-1G	305					1		20	31		32	1	20				-			SPARE
-----		305							33		34	1	20					-		SPARE
-----			305				3		35		36	1	20						-	SPARE
AC-1G	2522					1		20	37		38		150			1	3500			TRANSFORMER "TC"
9.1 FLA		2522							39		40							3500		125 KVA
-----			2522				3		41		42	3							3500	-----
TOTALS:	9107	4083	4615														61100	60603	63605	
																	TOTALS:	108703	164683	110915
																		A	B	C

86,970 V.A. (L.G.L) x 125 = 108,713 V.A.
OTHER LOAD = 123,615 V.A.
TOTAL = 232,328 V.A. TOTAL AMPS 279

* NOTE: PROVIDE TIME SWITCH "TORK #DZ5400A" AND CONTACTORS, SQUARE D CLASS 8903 TYPE LG40 (2 EA.) TO CONTROL EXTERIOR LIGHTING CIRCUITS HC-5a, HC-7a (1 CHANNEL) AND HC-5b, HC-7b (1 CHANNEL.) MOUNT TIME SWITCH AND CONTACTORS IN TOP OF PANEL "HC" IN SEPARATE BARRIERED COMPARTMENT WITH DOOR LOCKED KEYED TO MATCH PANEL. CONNECT TIME SWITCH AND LIGHTING CONTACTOR CONTROL CIRCUIT TO HC-4.

PANEL "HM"

MAIN 100A, 3P — BUSS 100A CU. — SERVICE 480/277V, 3Ø, 4W — LOCATION MAINTENANCE — MOUNTING SURFACE — A.I.C. 14,000

DESCRIPTION	VOLT AMPS A	B	C	LTG	RECP	MOT	BKR POLE	AMP	CKT NO.	A B C	CKT NO.	BKR POLE	AMP	LTG	RECP	MOT	VOLT AMPS A	B	C	DESCRIPTION
* MAINT.STORAGE LTS.	2360			8			1	20	1		2		40			1	0000			TRANSFORMER "TM"
RESTRM.OFF.EXIT LTS.		94		5			1	20	3		4							0000		50 KVA
* EXTERIOR LIGHTS			406	7			1	20	5		6	3							0000	-----
LIGHTING CONTROL	200					1	1	20	7		8	1	20				-			SPARE
WH-3		5500				1	1	30	9		10	1	20					-		SPARE
SPARE			-				1	20	11		12	1	20						-	SPARE
SPACE	-						1	-	13		14	1	-				-			SPACE
SPACE		-					1	-	15		16	1	-					-		SPACE
SPACE			-				1	-	17		18	1	-						-	SPACE
SPACE	-						1	-	19		20	1	-				-			SPACE
SPACE		-					1	-	21		22	1	-					-		SPACE
SPACE			-				1	-	23		24	1	-						-	SPACE
SPACE	-						1	-	25		26	1	-				-			SPACE
SPACE		-					1	-	27		28	1	-					-		SPACE
SPACE			-				1	-	29		30	1	-						-	SPACE
TOTALS:	2560	5594	406														0000	0000	0000	
																	TOTALS:	2560	5594	0406
																		A	B	C

2,860 V.A. (L.G.L) x 125 = 3,575 V.A.
OTHER LOAD = 55,700 V.A.
TOTAL = 59,275 V.A. TOTAL AMPS 47

* NOTE: PROVIDE TIME SWITCH "TORK #DZ5400A" AND CONTACTORS, SQUARE D CLASS 8903 TYPE LG40 (2 EA.) TO CONTROL EXTERIOR LIGHTING CIRCUITS HM-5a AND HM-5b (EACH ON A SEPARATE CHANNEL.) MOUNT TIME SWITCH AND CONTACTORS IN TOP OF PANEL "HM" IN SEPARATE BARRIERED COMPARTMENT WITH DOOR LOCKED KEYED TO MATCH PANEL. CONNECT TIME SWITCH AND LIGHTING CONTACTOR CONTROL CIRCUIT TO HM-7.

PANEL "HSG1"

MAIN 600A, 3P — BUSS 600A CU. — SERVICE 480/277V, 3Ø, 4W — LOCATION STADIUM CLUB BLDG. — MOUNTING SURFACE — A.I.C. 22,000

DESCRIPTION	VOLT AMPS A	B	C	LTG	RECP	MOT	BKR POLE	AMP	CKT NO.	A B C	CKT NO.	BKR POLE	AMP	LTG	RECP	MOT	VOLT AMPS A	B	C	DESCRIPTION
EF-15	832					1		20	1		2		20			1	832			GHJ-1S
-----		832							3		4							832		
-----			832				3		5		6	3							832	-----
AC-1S	3991					1		30	7		8		30			1	3991			AC-4S
14.4 FLA		3991							9		10							3991		14.4 FLA
-----			3991				3		11		12	3							3991	-----
AC-2S	3215					1		20	13		14		50			1	8203			AC-3S
11.6 FLA		3215							15		16							8203		29.6 FLA
-----			3215				3		17		18	3							8203	-----
AC-3S	3215					1		20	19		20		30			1	3991			AC-6S
11.6 FLA		3215							21		22							3991		14.4 FLA
-----			3215				3		23		24	3							3991	-----
GU-2S	9035					1		50	25		26	1	-				-			SPACE
32.6 FLA		9035							27		28	1	-					-		SPACE
-----			9035				3		29		30	1	-						-	SPACE
SPACE	-						1	-	31		32	1	-				-			SPACE
SPACE		-					1	-	33		34	1	-					-		SPACE
SPACE			-				1	-	35		36	1	-						-	SPACE
PANEL "HSG2"	1665						100		37		38		300			1	15000			TRANSFORMER "TSG"
-----		1552							39		40							15000		225 KVA
-----			1883				3		41		42	3							15000	"PANEL LSG1"
TOTALS:	2430	13540	20871														42071	42071	42071	
																	TOTALS:	124651	126071	122888
																		A	B	C

36,703 V.A. (L.G.L) x 125 = 45,879 V.A.
OTHER LOAD = 336,277 V.A.
TOTAL = 382,156 V.A. TOTAL AMPS 460

PANEL "HSG2"

MAIN LG — BUSS 225A CU. — SERVICE 480/277V, 3Ø, 4W — LOCATION STADIUM CLUB BLDG. — MOUNTING SURFACE — A.I.C. 22,000

DESCRIPTION	VOLT AMPS A	B	C	LTG	RECP	MOT	BKR POLE	AMP	CKT NO.	A B C	CKT NO.	BKR POLE	AMP	LTG	RECP	MOT	VOLT AMPS A	B	C	DESCRIPTION
CORRDR.STORMENS LTS.	1554			24			1	20	1		2		20			1	2500			MZ-Y
KITCHSERV.ARG.KONN LT.		1371		24			1	20	3		4	2						2500		YANKEE STADIUM
VESTIBULE.EXIT LTS.			975	34			1	20	5		6		20			1			2500	MZ-D
EXTERIOR CANOPY LTS.	1914			33			1	20	7		8	2					2500			DODGER STADIUM
FLOODLIGHTS		1876		4			1	20	9		10		20			1		2500		MZ-F
FLOODLIGHTS			1876	4			1	20	11		12	2							2500	FENWAY PARK
EXTERIOR BUILDING LTS.	232			4			1	20	13		14		20			1	2500			MZ-A
RESTAURANT DOWNLIGHTS	990			18			1	20	15		16	2						2500		ANGEL STADIUM
DINING RM 5G01 DOWNLTS			1045	19			1	20	17		18		1	20		1			500	LIGHTING CONTROL PANEL
DINING RM 5G01 DOWNLTS	990			18			1	20	19		20		1	20			-			SPARE
DINING RM 5G03 DOWNLTS	990			18			1	20	21		22		1	20				-		SPARE
DINING RM 5G03 DOWNLTS			1045	19			1	20	23		24		1	20					-	SPARE
GUEST 5I3 DOWNLIGHTS	440			8			1	20	25		26		1	-			-			SPACE
BAR 5I1 DOWNLIGHTS		825		15			1	20	27		28		1	-				-		SPACE
BAR 5I1 DOWNLIGHTS			342	14			1	20	29		30		1	-					-	SPACE
SPARE	-						1	20	31		32		1	-			-			SPACE
SPARE		-					1	20	33		34		1	-				-		SPACE
SPARE			-				1	20	35		36		1	-					-	SPACE
SPACE	-						1	-	37		38		1	-			-			SPACE
SPACE		-					1	-	39		40		1	-				-		SPACE
SPACE			-				1	-	41		42		1	-					-	SPACE
TOTALS:	4130	6052	5335														7500	7500	5500	
																	TOTALS:	12430	13552	10835
																		A	B	C

16,315 V.A. (L.G.L) x 125 = 20,394 V.A.
OTHER LOAD = 20,500 V.A.
TOTAL = 40,894 V.A. TOTAL AMPS 44



NOTE:

FEEDER LENGTHS SHOWN ARE FOR VOLTAGE DROP CALCULATIONS ONLY AND SHALL NOT BE USED FOR BID TAKE-OFF.

SINGLE LINE DIAGRAM NOTES

1. BUILDING GROUND SYSTEM. 3/4"G - 1 #2 GRD THAN CU TO UFER GROUND. PROVIDE MINIMUM 20 FOOT OF 1 #2 B.C. WITH 2" MINIMUM CONCRETE ENGASEMENT AT BOTTOM OF BUILDING FOOTING. BOND TO BUILDING COLD METALLIC WATER PIPE, GAS PIPE AND BUILDING STEEL WITH 1 #2 GRD THAN CU.
2. BUILDING GROUND SYSTEM. 1"G - 1 #3/0 GRD THAN CU TO UFER GROUND. PROVIDE MINIMUM 20 FOOT OF 1 #3/0 B.C. WITH 2" MINIMUM CONCRETE ENGASEMENT AT BOTTOM OF BUILDING FOOTING. BOND TO BUILDING COLD METALLIC WATER PIPE, GAS PIPE AND BUILDING STEEL WITH 1 #3/0 GRD THAN CU.
3. 3/4"G - 1 #2 THAN. CU TO PANEL "HA" GROUND BUS.
4. 1"G - 1 #3/0 THAN. CU TO PANEL "HC" GROUND BUS.
5. 3/4"G - 1 #2 THAN. CU TO PANEL "HM" GROUND BUS.
6. 1"G - 1 #3/0 THAN. CU TO PANEL "HSG1" GROUND BUS.
7. ALL PANELS AND DISCONNECTS SHALL BE IDENTIFIED ON THE OUTSIDE AS TO EQUIPMENT OR AREAS SERVED.
8. INDICATES ENCLOSURE TYPE.

SINGLE LINE DIAGRAM NOT TO SCALE

PANEL SCHEDULE INDEX

	HA	HC
		HM
		HSG1
		HSG2

MIG
MOORE IACOFANO GOLTSMAN, INC.
601 N. HARBOR BLVD. FULLERTON, CA 92831
TEL 714/871-3559 FAX 714/871-1120
www.migcom.com

PITASSI ARCHITECTS, INC.
8439 White Oak Ave., Suite. 105
Rancho Cucamonga, Ca 91730
Tel. 909-980-1361 ▪ Fax. 909-944-5814
e-mail. pjpaia@pitassiarchitects.com

CONSULTANT:

LRA ENGINEERS
Electrical Consulting Engineers
1471 Pomona Road, Unit E
Corona, California 92880
Tel: (951) 737-4569 Fax: (951) 737-5619

PERRIS VALLEY Big League Dreams

2155 Trumble Road
Perris, California 92570

SHEET TITLE
SINGLE LINE DIAGRAM & PANELBOARD SCHEDULES

100% CONSTRUCTION DOCUMENT

DATE	REVISIONS

STAMP

REGISTERED PROFESSIONAL ENGINEER — DONALD C. REGALADO — No. E18914 — Exp. 6.30.11 — ELECTRICAL — STATE OF CALIFORNIA

CHECKED BY	DATE
LRA	
DATE 01-07-10	FILE NAME
DRAWN BY CR	SHEET EB-0.3
JOB NO. 05208.00	
SCALE NONE	163 OF 313 SHEETS