| | | | | | | | | | | | | | | | | | TOTAL |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | MONTHS OF OPERATION | | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG. | SEP. | OCT. | NOV. | DEC. | / YEAR |
| | DESIRED MO.APPL. | | MONTHLY EVAP. RATE | | 1.55 | 2.52 | 4.03 | 5.7 | 7.75 | 8.7 | 9.3 | 8.37 | 6.3 | 4.34 | 2.4 | 1.55 | 62.51 |
| CONTROLL | VALVE # | HD. TYPE | SPR. PR. | DAYS OPER | stat.op/time | | | | | | | | | | | | |
| G | 1 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 2 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| G | 3 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| G | 4 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 5 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| G | 6 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 7 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 8 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| G | 9 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| G | 10 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 11 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 12 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 13 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| G | 14 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| G | 15 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| G | 16 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| G | 17 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 18 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 19 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 20 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 21 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 22 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 23 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| G | 24 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| | **TOTAL HOURS OF OPERATION** | | | | **1.0** | **1.7** | **2.7** | **3.8** | **5.1** | **5.7** | **6.1** | **5.5** | **4.2** | **2.9** | **1.6** | **1.0** | |

**THE TIMES AS POSTED ABOVE ARE TO BE USED AS A GUIDE AND WILL HAVE TO BE ADJUSTED FOR SITE CONDITIONS.**

| | | | | | | | | | | | | | | | | | TOTAL |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | MONTHS OF OPERATION | | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG. | SEP. | OCT. | NOV. | DEC. | / YEAR |
| | DESIRED MO.APPL. | | MONTHLY EVAP. RATE | | 1.55 | 2.52 | 4.03 | 5.7 | 7.75 | 8.7 | 9.3 | 8.37 | 6.3 | 4.34 | 2.4 | 1.55 | 62.51 |
| CONTROLL | VALVE # | HD. TYPE | SPR. PR. | DAYS OPER | stat.op/time | | | | | | | | | | | | |
| H | 1 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 2 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 3 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| H | 4 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 5 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 6 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| H | 7 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 8 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| H | 9 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| H | 10 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| H | 11 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 12 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 13 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| H | 14 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| H | 15 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| H | 16 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| | **TOTAL HOURS OF OPERATION** | | | | **0.9** | **1.4** | **2.3** | **3.3** | **4.4** | **5.0** | **5.3** | **4.8** | **3.6** | **2.5** | **1.4** | **0.9** | |

**THE TIMES AS POSTED ABOVE ARE TO BE USED AS A GUIDE AND WILL HAVE TO BE ADJUSTED FOR SITE CONDITIONS.**

| | | | | | | | | | | | | | | | | | TOTAL |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | MONTHS OF OPERATION | | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG. | SEP. | OCT. | NOV. | DEC. | / YEAR |
| | DESIRED MO.APPL. | | MONTHLY EVAP. RATE | | 1.55 | 2.52 | 4.03 | 5.7 | 7.75 | 8.7 | 9.3 | 8.37 | 6.3 | 4.34 | 2.4 | 1.55 | 62.51 |
| CONTROLL | VALVE # | HD. TYPE | SPR. PR. | DAYS OPER | stat.op/time | | | | | | | | | | | | |
| I | 1 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| I | 2 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| I | 3 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| I | 4 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| I | 5 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| I | 6 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| I | 7 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| I | 8 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| I | 9 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| I | 10 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| I | 11 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| I | 12 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| I | 13 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| I | 14 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| I | 15 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| I | 16 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 17 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| I | 18 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 19 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 20 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 21 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 22 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 23 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| I | 24 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| | **TOTAL HOURS OF OPERATION** | | | | **1.0** | **1.6** | **2.6** | **3.7** | **5.0** | **5.6** | **6.0** | **5.4** | **4.0** | **2.8** | **1.5** | **1.0** | |

**THE TIMES AS POSTED ABOVE ARE TO BE USED AS A GUIDE AND WILL HAVE TO BE ADJUSTED FOR SITE CONDITIONS.**

| | | | | | | | | | | | | | | | | | TOTAL |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | MONTHS OF OPERATION | | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG. | SEP. | OCT. | NOV. | DEC. | / YEAR |
| | DESIRED MO.APPL. | | MONTHLY EVAP. RATE | | 1.55 | 2.52 | 4.03 | 5.7 | 7.75 | 8.7 | 9.3 | 8.37 | 6.3 | 4.34 | 2.4 | 1.55 | 62.51 |
| CONTROLL | VALVE # | HD. TYPE | SPR. PR. | DAYS OPER | stat.op/time | | | | | | | | | | | | |
| J | 1 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 2 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 3 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 4 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 5 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 6 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 7 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 8 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| J | 9 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| J | 10 | BUBBLER | 2.6 | 6 | 1 | 2 | 4 | 5 | 7 | 8 | 9 | 8 | 6 | 4 | 2 | 1 | |
| J | 11 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| J | 12 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| J | 13 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| J | 14 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| J | 15 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| J | 16 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 17 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 18 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 19 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 20 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 21 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 22 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 23 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| J | 24 | | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| | **TOTAL HOURS OF OPERATION** | | | | **1.0** | **1.6** | **2.6** | **3.7** | **5.0** | **5.6** | **6.0** | **5.4** | **4.1** | **2.8** | **1.5** | **1.0** | |

**THE TIMES AS POSTED ABOVE ARE TO BE USED AS A GUIDE AND WILL HAVE TO BE ADJUSTED FOR SITE CONDITIONS.**

| | | | | | | | | | | | | | | | | | TOTAL |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | MONTHS OF OPERATION | | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG. | SEP. | OCT. | NOV. | DEC. | / YEAR |
| | DESIRED MO.APPL. | | MONTHLY EVAP. RATE | | 1.55 | 2.52 | 4.03 | 5.7 | 7.75 | 8.7 | 9.3 | 8.37 | 6.3 | 4.34 | 2.4 | 1.55 | 62.51 |
| CONTROLL | VALVE # | HD. TYPE | SPR. PR. | DAYS OPER | stat.op/time | | | | | | | | | | | | |
| K | 1 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 2 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| K | 3 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 4 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 5 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 6 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 7 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 8 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| K | 9 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| K | 10 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 11 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 12 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 13 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 14 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 15 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 16 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 17 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 18 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 19 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 20 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 21 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 22 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 23 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| K | 24 | ROT-PC | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| K | 25 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 26 | EMITTER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 27 | SPRAY | 1.6 | 6 | 2 | 4 | 6 | 9 | 12 | 14 | 15 | 13 | 10 | 7 | 4 | 2 | |
| K | 28 | BUBBLER | 100 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| K | 29 | STRM. ROT. | 0.6 | 6 | 6 | 11 | 17 | 24 | 32 | 36 | 39 | 35 | 26 | 18 | 10 | 6 | |
| K | 30 | | | | | | | | | | | | | | | | |
| K | 31 | | | | | | | | | | | | | | | | |
| K | 32 | | | | | | | | | | | | | | | | |
| | **TOTAL HOURS OF OPERATION** | | | | **1.0** | **1.7** | **2.6** | **3.7** | **5.1** | **5.7** | **6.1** | **5.5** | **4.1** | **2.9** | **1.6** | **1.02** | |

**THE TIMES AS POSTED ABOVE ARE TO BE USED AS A GUIDE AND WILL HAVE TO BE ADJUSTED FOR SITE CONDITIONS.**

| | | | | | | | | | | | | | | | | | TOTAL |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | MONTHS OF OPERATION | | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG. | SEP. | OCT. | NOV. | DEC. | / YEAR |
| | DESIRED MO.APPL. | | MONTHLY EVAP. RATE | | 1.55 | 2.52 | 4.03 | 5.7 | 7.75 | 8.7 | 9.3 | 8.37 | 6.3 | 4.34 | 2.4 | 1.55 | 62.51 |
| CONTROLL | VALVE # | HD. TYPE | SPR. PR. | DAYS OPER | stat.op/time | | | | | | | | | | | | |
| L | 1 | ROT-PC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 2 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 3 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 4 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 5 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 6 | ROT-PC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 7 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 8 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 9 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 10 | ROT-PC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 11 | BUBBLER | 2.6 | 7 | 1 | 2 | 3 | 5 | 6 | 7 | 8 | 7 | 5 | 4 | 2 | 1 | |
| L | 12 | SPRAY | 1.6 | 7 | 2 | 3 | 5 | 8 | 10 | 12 | 12 | 11 | 8 | 6 | 3 | 2 | |
| L | 13 | SPRAY | 1.6 | 7 | 2 | 3 | 5 | 8 | 10 | 12 | 12 | 11 | 8 | 6 | 3 | 2 | |
| L | 14 | ROT-PC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 15 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 16 | ROT-FC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| L | 17 | ROT-PC | 0.6 | 7 | 6 | 9 | 14 | 20 | 28 | 31 | 33 | 30 | 23 | 16 | 9 | 6 | |
| | **TOTAL HOURS OF OPERATION** | | | | **1.3** | **2.1** | **3.4** | **4.7** | **6.4** | **7.2** | **7.7** | **7.0** | **5.2** | **3.6** | **2.0** | **1.3** | |

**THE TIMES AS POSTED ABOVE ARE TO BE USED AS A GUIDE AND WILL HAVE TO BE ADJUSTED FOR SITE CONDITIONS.**

## EMWD Construction Note

EASTERN MUNICIPAL WATER DISTRICT REQUIRES THAT A PRE-CONSTRUCTION CONFERENCE BE SCHEDULED PRIOR TO ANY CONSTRUCTION BY CALLING THE EASTERN MUNICIPAL WATER DISTRICT FIELD ENGINEERING DEPARTMENT AT (951) 928-3777, EXTENSION 4830.

## Omission Statement

THERE ARE NO , DECORATIVE FOUNTAINS, OUTDOOR EATING AREAS, OR WELLS ON THE SITE.
DRINKING WATER FOUNTAINS, DESIGNATED OUTDOOR EATING AREAS, PLAY AREAS, RESTAURNTS & RESTROOMS SHALL BE PROTECTED AGAINST CONTACT WITH RECYCLED WATER SPRAY, MIST, OR RUN-OFF. THE POTABLE WATERLINE SUPPLYING THE DRINKING FOUNTAIN MUST HAVE A WARNING BLUE COLORED TAPE IDENTIFYING IT AS A POTABLE WATERLINE AND STATING "CAUTION: BURIED WATERLINE BELOW" INSTALLED OVER IT.

## Potable and Recycled Water Separation Note

RECYCLED MAINLINE (CONSTANT PRESSURE) SHOWN DIAGRAMMATICALLY FOR CLARITY ONLY. ACTUAL LOCATION MUST PROVIDE A MINIMUM FOUR (4) FEET HORIZONTAL CLEARANCE BETWEEN ALL POTABLE AND CONSTANT PRESSURE RECYCLED WATERLINES. RECYCLED WATER MAINLINE SHOULD BE INSTALLED UNDER POTABLE WATERLINES AND MAINTAIN ONE (1) FOOT OF VERTICAL CLEARANCE. WHERE THE RECYCLED WATER CONSTANT PRESSURE LINE MUST BE INSTALLED ABOVE THE POTABLE WATERLINE, A FOUR (4) INCH MINIMUM VERTICAL CLEARANCE MUST BE MAINTAINED AND THE RECYCLED WATER PRESSURE LINE MUST BE INSTALLED IN A CONTINUOUS PVC CLASS 200 PIPE OR GREATER SLEEVE WHICH EXTENDS A MINIMUM OF TEN (10) FEET EACH SIDE OF THE POTABLE WATERLINE.


MOORE IACOFANO GOLTSMAN, INC.
801 HARBOR BLVD.
FULLERTON, CA 92832
TEL 714/871-3638
FAX 714/871-1188
www.migcom.com

BILL L. WILLIAMS
IRRIGATION DESIGN & CONSULTANT
2518 E. Roberta Dr. Orange, Ca. 92869
CELL 714-309-9833, FAX 714-997-0344
bill@williamsidc.com e-mail


PROJECT TEAM:
LANDSCAPE ARCHITECT
MIG INC.

ARCHITECT
PITASSI ARCHITECTS INC.

CIVIL ENGINEERS/SURVEYOR
WALDEN & ASSOCIATES

STRUCTURAL ENGINEERS
CORREIA CONSULTING & DESIGN

ELECTRICAL ENGINEERS
LRA ENGINEERS

IRRIGATION DESIGNER
WILLIAMS IRRIGATION DESIGN

GEOTECHNICAL ENGINEERS
CONVERSE CONSULTANTS

TURF GRASS CONSULTANT
GUISE AND ASSOCIATES

# PERRIS VALLEY Big League Dreams

2155 Trumble Road
Perris, California, 92570

SHEET TITLE

# IRRIGATION DETAILS

100% CONSTRUCTION DOCUMENT

| DATE | REVISIONS |
|---|---|
| | |

STAMP

LICENSED LANDSCAPE ARCHITECT
STEVEN N. LANG NO. 1771
SIGNATURE 11-30-10
RENEWAL DATE 07-07-10
DATE
STATE OF CALIFORNIA

| CHECKED BY | DATE |
|---|---|
| BLW | 07-22-09 |
| DATE 07-30-09 | FILE NAME |
| DRAWN BY BLW | SHEET |
| JOB NO. 05208.00 | LI-2.7 |
| SCALE NO SCALE | 287 OF 313 SHEETS |

Underground Service Alert
CALL BEFORE YOU DIG
Call: TOLL FREE
1-800-227-2600
TWO WORKING DAYS BEFORE YOU DIG


MOORE IACOFANO GOLTSMAN, INC.
801 HARBOR BLVD.
FULLERTON, CA 92832
TEL 714/871-3638
FAX 714/871-1188
www.migcom.com


| DESCRIPTION | | | | | |
|---|---|---|---|---|---|
| DATE | BY | MARK | | APPR. | DATE |
| ENGINEER | | | REVISIONS | EMWD | |

ON-SITE RECYCLED WATE APPROVAL BY:
EASTERN MUNICIPAL WATER DISTRICT

CIVIL ENGINEER OF SUBDIVISIONS — DATE

| APPROVALS | | INITIAL | DATE |
|---|---|---|---|
| | PROJECT ENGR. | | |
| | OPERATION | | |
| | W.O. | S.A. | COORD. |

COUNTY OF "RIVERSIDE"

APN-327-190-019
RECYCLED WATER LANDSCAPE IMPROVEMENT PLANS
PERRIS VALLEY BIG LEAGUE DREAMS
DETAIL SHEET

W.O. 12711
I.D. 98
S.A. 37
COORD. 37C-43
SHT. LI-2.7 OF 15
SO
D-'