

REQUEST FOR INFORMATION FORM

PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92631
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3/26/2010

CONTRACTOR: ValleyCrest Landscape Development

CONTACT PERSON: Stephen Aguirre

ADDRESS: 8450 Miramar Placc, San Diego, CA 92121

TELEPHONE NUMBER: (858)458-9900

FACSIMILE NUMBER: (858)458-0842

Specification Section:	Paragraph:	Drawing Reference:	Detail:
		LD-4.2a; LM-1; LM-2	

Request: Plan sheet LD-4.2a shows two flagpoles at the center outfield for the Dodger Stadium replica. Plan sheets LM-1 and LM-2, while calling out the site flagpoles and the Angel Stadium flagpoles does not identify the Dodger flagpoles. Please clarify the models numbers and finishes.

Signed by:

Response:

Dodger Stadium shall receive two 35' high galvanized flagpoles.

Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

REQUEST FOR INFORMATION FORM

PERRIS VALLEY -- BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3/26/2010

CONTRACTOR: ValleyCrest Landscape Development

CONTACT PERSON: Stephen Aguirre

ADDRESS: 8450 Miramar Place, San Diego, CA 92121

TELEPHONE NUMBER: (858)458-9900

FACSIMILE NUMBER: (858)458-0842

Specification Section:	Paragraph:	Drawing Reference:	Detail:
02900	Part 2 - item G	L-3.7, C2.02	

Request: Sheet L-3.7 refers to the specifications for details regarding the bioswale growing medium. No depths are noted in the Technical Specifications or the civil plans. Please clarify the required depth of the bioswale growing medium.

Signed by:

Response:

Bioswale Growing Medium shall be placed in all parking lot areas as indicated on plans at a depth of 18". Detail 'C', Sheet L3.7 is a typical installation of the bioswale medium. All end caps, planting diamonds shall receive medium. Also reference RFI #50 regarding irrigation is planting diamonds with no tree.

Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form. Multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

REQUEST FOR INFORMATION FORM

PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3/26/2010

CONTRACTOR: ValleyCrest Landscape Development

CONTACT PERSON: Stephen Aguirre

ADDRESS: 8450 Miramar Place, San Diego, CA 92121

TELEPHONE NUMBER: (858)458-9900

FACSIMILE NUMBER: (858)458-0842

Specification Section:	Paragraph:	Drawing Reference:	Detail:
		L-1.7	D

Request: Detail D/LD-1.7 show the detail for the 12' bridge at Tot-Lot number 2. There is no callout for a manufacturer or model number in the plans or specifications. Please provide.

Signed by:

Response:

Please refer to RFI #31

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m. ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form. Multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFIs via email will be accepted.

RFI # 43
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3/29/10
3/22/10

CONTRACTOR: HARBOR CONSTRUCTION CO. LLC
CONTACT PERSON: STEVE PADILLA
ADDRESS: 15550 ROCKFIELD BLVD B-100 IRVING, CA 92618
TELEPHONE NUMBER: 949-457-1888
FACSIMILE NUMBER: 949-457-9888

Specification Section: 16742 Paragraph: Part 1 Item 1.2.2 Drawing Reference: EB0.1 Detail:

Request: Section 16742 - Communication & Data Processing Equipment Part 1 item 1.2.2 states "Computer Hardware and Software Provided and Installed by DIBS under contract by GC, CMR, or City."
The Telephone and Data Legend on drawing EB0.1 calls out for 3/4" conduit only for this system.
a. It is assumed that the furnishing and installation of the Data Processing equipment, hardware and software, work to be performed by DIBS, will be performed under a contract directly with CMR or the City and not the GC. Is this correct? If not please clarify.
b. It is assumed that the cabling for the telephone and data system is to be installed by DIBS under a direct contract with CMR or the City and not the GC. Is this correct? If not please clarify.

Signed by: [Signature]
Response:

The phone system and cabling shall be provided by the GC.
The cabling for the hardware/software shall be provided by the GC.
The actual hardware/software will be provided by DIBS.

[] Attachments

Response From: Robert Echavarria - M.I.G.
Signed by: _____
Date: 04/01/10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 44
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3/29/2010

CONTRACTOR: EDGE DEVELOPMENT
CONTACT PERSON: CEL DELLEY
ADDRESS: 21362 NIATINDUSOLA TEMECULA CA
TELEPHONE NUMBER: 951 796 0176
FACSIMILE NUMBER: 951 796 0115

Specification Section: 100.6 Paragraph: 1 Drawing Reference: AA Detail: NA

Request:

WE ARE IN RECEIPT OF ADDENDUM 6 AND HAVE NOTED THE BID DATE CHANGE ~~TO~~ TO APRIL 13. THE BID DATE TIME OF 8:30 AM PUTS AN UN DUE HANDSHP ON THE GENERAL CONTRACTORS BIDDING. PLEASE CONSIDER CHANGING THE BID TIME TO 2:00 PM.

Signed by: [Signature]

Response:

Date and time were chosen due to the availability of the Council Chambers.

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., Ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3-29-2010

CONTRACTOR: American Landscape, Inc.
CONTACT PERSON: Jamie Tsui / Jason Strauss
ADDRESS: _____
TELEPHONE NUMBER: (818) 999-2041
FACSIMILE NUMBER: (818) 999-2056

Specification Section: 02547 Paragraph:

Drawing Reference: LD-3.3

Detail: D

Request:

1. Specifications 02547 indicate a 3" depth for the warning track mix. Detail D / Sheet LD3.3 indicates 4" depth. Please clarify proper depth.

Signed by:

Response:

Warning track shall be placed at a depth of 4" over aggregate base, as per Detail D/LD-3.3. Also refer to RFI #46 for further clarification.

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3-29-2010

CONTRACTOR: American Landscape, Inc.
CONTACT PERSON: Jamie Tsui / Jason Strauss
ADDRESS: _____
TELEPHONE NUMBER: (818) 999-2041
FACSIMILE NUMBER: (818) 999-2056

Specification Section: _____ Paragraph: _____ Drawing Reference: LD-3.3 Detail: D

Request:

2. Detail D / Sheet LD3.3 indicates Class II Aggregate base below the warning track / infield mix, however the call out specifies at the warning track. Please clarify the areas to received this base material.

Signed by: _____

Response: _____

Aggregate base is for the warning tracks only. Infield shall be compacted subgrade. Please read Detail "D", Sheet LD-3.3 carefully.

Attachments

Response From: _____

Signed by: _____

Date: _____

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3-29-2010

CONTRACTOR: American Landscape, Inc.
CONTACT PERSON: Jamie Tsui / Jason Strauss
ADDRESS: _____
TELEPHONE NUMBER: (818) 999-2041
FACSIMILE NUMBER: (818) 999-2056

Specification Section: 02547 Paragraph:

Drawing Reference: LD-1.1

Detail: 0

Request:

Decomposed granite per detail O / Sheet LD-1.1 indicates a difference application procedure for the stabilized decomposed granite. This detail conflicts with the specifications. Please verify the proper application procedure for the decomposed granite.

Signed by:

Response:

The application procedure for the D.G. shall be per the specification section 02547. Detail 'O', Sheet LD-1.1 shall be used to detail the concrete strips adjacent to the pathways.

[] Attachments

Response From: Robert Echavarria - M.I.G.
Signed by: _____
Date: 04-01/10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFIs via email will be accepted.

RFI # 48
Official use only

REQUEST FOR INFORMATION FORM

PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3-29-2010

CONTRACTOR: Marina Landscape, Inc.
CONTACT PERSON: Joe Fuentes
ADDRESS: 1900 S. Lewis St. Anaheim, CA 92805
TELEPHONE NUMBER: 714.704.0470
FACSIMILE NUMBER: 714.935.0797

Specification Section: 02900 Paragraph: Part 2-Materials (S.) Drawing Reference: L3.1, L3.7 Detail: C-L3.7

Request:

Please clarify depth of Bio-Swale Growing Medium as shown on drawing references listed above. Also clarify the area of placement for the Growing Medium. Plan sheet L3.1 shows a different graphic for these areas than does plan sheet L3.7, Detail 'C'.

Signed by: [Signature]

Response:

Bioswale Growing Medium shall be placed in all parking lot areas as indicated on plans at a depth of 18". Detail 'C', Sheet L3.7 is a typical installation of the bioswale medium. All end caps, planting diamonds shall receive medium. Also reference RFI #50 regarding irrigation is planting diamonds with no tree.

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

REQUEST FOR INFORMATION FORM

PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: March/30/2010

CONTRACTOR: Adame Landscape
CONTACT PERSON: Ivan F. Velazquez
ADDRESS: 41863 Juniper St. Murrieta, CA
TELEPHONE NUMBER: See Below
FACSIMILE NUMBER: See Below

Specification Section: _____ Paragraph: _____ Drawing Reference: L3.7 Detail: _____

Request:

SHEET L3.7 DETAIL 'C' TYPICAL PARKING LOT PLANTING ISLAND
IS INDICATING THAT ALL OF THE ISLANDS AND HALF DIAMOND
POP-OUTS ARE TO RECEIVE VEGETATED HYDROSEED MIX. HOWEVER
PLANTING PLANS SHOW SOME OF THE HALF DIAMOND POP-OUTS W/O^{UT}
TREES PLANTED IN THEM AND IN ADDITION ARE NOT IRRIGATED.
PLEASE VERIFY IF THE HALF DIAMOND POP-OUTS W/O^{UT} THE TREES

Signed by:



ARE GOING TO BE HYDROSEEDED AND IRRIGATED.

Response:

All planting half diamonds are to receive the hydroseed/Bioswale seed mixture. The diamonds without trees shall have irrigation. Contractor shall bid a price to completely irrigation the planting diamonds, regardless of a tree.

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 51
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 03-29-10

CONTRACTOR: JAYNES CORP.
CONTACT PERSON: CRAIG NOEL
ADDRESS: 111 ELM ST., SAN DIEGO, CA
TELEPHONE NUMBER: 619-233-4080
FACSIMILE NUMBER: 619-233-4090

Specification Section: Paragraph: Drawing Reference: Detail:
LD4.1C D

Request: DETAIL D AND NOTE ON B INDICATE EXTIRA BOARD TO WITHIN 4" OF GRADE BUT DETAIL D REFERS TO STRUCTURAL PLANS (YS-3) THAT SHOWS THE EXTERIOR SIDE EXTIRA BOARD STOPPING AT THE HSS 6X. PLEASE CLARIFY THE EXTENT OF THE EXTERIOR EXTIRA BOARD FOR THE BASE BID AND ALTERNATE 2.

Signed by: CN

Response:

Extira board is required as the base bid and should stop HSS 6x as indicated on structural drawings. Below the HSS 6x shall receive the ornamental fencing per the drawings and specifications. This is for the backside of the wall only.
Add. alt (#2) is for the foam plant-ons and painting of the plant ons only.
Also reference RFI # 21

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 52
Official use only

REQUEST FOR INFORMATION FORM

PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 03-29-10

CONTRACTOR: JAYNES CORP.
CONTACT PERSON: CRAIG NOEL
ADDRESS: 111 ELM ST., SAN DIEGO, CA
TELEPHONE NUMBER: 619-233-4080
FACSIMILE NUMBER: 619-233-4090

Specification Section: Paragraph: Drawing Reference: FS-3 Detail: 1

Request: HOW FAR DOWN
DOES THE EXTERIOR SIDE EXTIRA BOARD
RUN AT THIS DETAIL LOCATION?

Signed by: CN

Response:

Extira board runs the length of the wall.

Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 53
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 03-29-10

CONTRACTOR: JAYNES CORP.
CONTACT PERSON: CRAIG NOEL
ADDRESS: 111 ELM ST., SAN DIEGO, CA
TELEPHONE NUMBER: 619-233-4080
FACSIMILE NUMBER: 619-233-4090

Specification Section: Paragraph: Drawing Reference: LD-5.2 Detail:

Request:

IS THERE BLEACHER SEATING REQUIRED
FOR ADD ALT. 1? TYPE + STYLE?

Signed by: CN

Response:

There are no "stadium style" bleacher seats required for Add Alt #1

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE. All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 54
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 03-29-10

CONTRACTOR: JAYNES CORP.
CONTACT PERSON: CRAIG NOEL
ADDRESS: 111 ELM ST., SAN DIEGO, CA
TELEPHONE NUMBER: 619-233-4080
FACSIMILE NUMBER: 619-233-4090

Specification Section: 03350 Paragraph: Drawing Reference: Detail:

- Request:
- 2.6 LITHOCHROME COLOR HARDENER
 - 2.8 EMERCHROME FLOOR HARDENER
 - 3.10.i SONNEBERN SEALER (AT FLOORS) → 2.11 OTHER SEALERS
 - 3.10.j SHAKE ON COLOR (FLOORS) → LS DWG INTEGRAL

THE LANDSCAPE DWGS. - LM-1 INDICATE DAVIS COLORS (INTEGRAL POWDER)
DO THE ITEMS LISTED ABOVE APPLY TO THE EXTERIOR FLATWORK
ON THIS PROJECT? IF SO, PLEASE SPECIFY.

Signed by: CN

Response:

Unless the requested items are listed in the Contract Drawings as an acceptable finished concrete surface, they are not intended to be used on the site work.

Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 55
Official use only

REQUEST FOR INFORMATION FORM

PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 03-29-10

CONTRACTOR: JAYNES CORP.
CONTACT PERSON: CRAIG NOEL
ADDRESS: 111 ELM ST., SAN DIEGO, CA
TELEPHONE NUMBER: 619-233-4080
FACSIMILE NUMBER: 619-233-4090

Specification Section: Paragraph: Drawing Reference: YS-1 Detail: C

Request:

CAN THE CAISSON CAPS BE DRILLED ROUND
OR ARE THEY INTENDED TO BE SQUARE?

Signed by: CN

Response:

Caissons caps should be square as detailed in sheet SD-2, detail 3

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 56
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd. Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3/29/10

CONTRACTOR: HARBOR CONSTRUCTION CO. LLC.
CONTACT PERSON: STEVE PADILLA
ADDRESS: 1550 ROCKFIELD BLVD B-100 PERRIS, CA
TELEPHONE NUMBER: 949-457-1888 92618
FACSIMILE NUMBER: 949-457-9888

Specification Section: Paragraph: Drawing Reference: Detail:

ADDENDUM #6 ITEM #1

Request:

THE BID DATE HAS BEEN CHANGED TO APRIL 13TH @ 8:30AM
PLEASE CONFIRM THE BID DATE TIME OF 8:30AM
THIS IS AN UNUSUAL TIME FOR A
PUBLIC WORKS BID.

Signed by: 

Response:

Date and time were chosen because of the availability of the Council Chambers.

[] Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.

RFI # 59
Official use only

REQUEST FOR INFORMATION FORM
PERRIS VALLEY - BIG LEAGUE DREAMS

BIDDING QUESTIONS TO:

M.I.G., Inc.
801 N. Harbor Blvd., Fullerton, CA 92831
Attention: Robert Echavarria - Project Manager
FAX: (714) 871-1188

DATE SUBMITTED: 3-30-2010

CONTRACTOR: EDGE
CONTACT PERSON: NEIL REILLY
ADDRESS: 27368 VIA INDUSTRIA, TEMECULA
TELEPHONE NUMBER: 951 296 0776
FACSIMILE NUMBER: 951 296 0775

Specification Section: 2 Paragraph: _____ Drawing Reference: L2.1 Detail: _____

Request: THE CONSTRUCTION LEGEND ON L2.1 ITEM 78
CAUSOUT 54" PRECAST BASEBALL
LM-2 CAUSOUT QUICKCRETE QR36BB WHICH
IS A 36" DIAMETER UNIT.
PLEASE PROVIDE CORRECT SIZE

Signed by: *Neil Reilly*

Response:

All Precast Concrete Baseballs from Quickcrete shall be 54" diameter (QR54-BB).

Attachments

Response From: Robert Echavarria - M.I.G.

Signed by: _____

Date: 04-01-10

NOTE: All questions must be received in writing on the form provided no later than 5:00 p.m., ten (10) working days prior to bid opening. This will allow time to respond to the question and/or to issue an addendum to all contractors addressing the question. Questions received after the due date will not be acknowledged. Please submit one question/request per form, multiple questions may not be answered unless pertaining to same RFI. Written requests via facsimile are encouraged to expedite process. No RFI's via email will be accepted.